

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087191-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009698

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MAIN KITCHEN
 EQUIPMENT STORE

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	3		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	3		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087192-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009699

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MAIN KITCHEN
PROD WASH AREA-1

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087193-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009700

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MAIN KITCHEN
 PROD WASH AREA-2

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	3		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	3		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:


Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

 Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087194-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009701

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MAIN KITCHEN
PROD WASH AREA-3

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	3		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	3		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087195-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009702

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MAIN KITCHEN
MAIN KITCHEN COUNTER-1

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087196-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009703

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MAIN KITCHEN
MAIN KITCHEN COUNTER-2

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087197-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009704

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MAIN KITCHEN
MAIN KITCHEN STOVE-1

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087198-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009705

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MAIN KITCHEN
 MAIN KITCHEN STOVE-2

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	<0.01		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	<0.01		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:


Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

 Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087199-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009706

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MAIN KITCHEN
 PASTRY AREA-1

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:


Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

 Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087200-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009707

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MAIN KITCHEN
PASTRY AREA-2

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087201-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009708

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MAIN KITCHEN
MAIN KITCHEN NEAR CHILLER-1

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	3		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	3		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087202-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009709

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MAIN KITCHEN
 MAIN KITCHEN NEAR CHILLER-2

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087203-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009710

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MAIN KITCHEN
 MAIN KITCHEN POINT

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:


Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

 Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087204-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009711

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MAIN KITCHEN
 DISH WASH AREA-1

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:


Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

 Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087205-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009712

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 30E MICRO KITCHEN
 MICRO KITCHEN SINK

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	3		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	3		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087206-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009713

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E MOTHERS ROOM
MOTHERS ROOM

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	2		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	2		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087207-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009714

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E BEVERAGE COUNTER
BEVERAGE COUNTER (ICE DISPENSER)

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	<0.01		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	<0.01		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087208-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009715

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 30E TOILET
SHOWER ROOM (MALE TOILET)

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	<0.01		-
	Legionella Pneumophila 2-15	cfu/ml	<1		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	<1		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087209-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009716

To: WAH LOON ENGINEERING PTE LTD
10 TAGORE DRIVE, WAH LOON BUILDING
787625 SINGAPORE
SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
LEVEL 18W MICRO KITCHEN
MICRO KITCHEN

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	<0.01		-
	Legionella Pneumophila 2-15	cfu/ml	<1		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	<1		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:



Shee Yen Lee
Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --

TEST REPORT

Page No: 1/1

Report No: AR-22-EZ-087210-01
Date of Issue: 28-Sep-2022

Batch No: EUAA46-00105971
Sample No: 747-2022-09009717

To: WAH LOON ENGINEERING PTE LTD
 10 TAGORE DRIVE, WAH LOON BUILDING
 787625 SINGAPORE
 SINGAPORE

Date Sample Received: 16-Sep-2022
Date of Testing: 16-Sep-2022 to 27-Sep-2022

Attn: YAR ZAR

Sample Description: MARINA ONE
 LEVEL 29E MOTHERS ROOM
 MOTHERS ROOM

Analysis Result(s):

Test	Bacteriological Analysis	Unit	Result	Test Method	Specification
EZ0R0	Total Legionella Count			ISO 11731:2017	
	Legionella Pneumophila 1	cfu/ml	<0.01		-
	Legionella Pneumophila 2-15	cfu/ml	<0.01		-
	Legionella Species	cfu/ml	<0.01		-
	Total Legionella	cfu/ml	<0.01		-

Test performed uses the latest edition of APHA, unless otherwise stated. The above result(s) is/are tested as per sample submitted in accordance with PUB's potable water quality (typical values) for water storage tanks.

This 1 page(s) of report and its attachment(s) if relevant has/have been validated by:


Shee Yen Lee
 Senior Microbiologist

EXPLANATORY NOTE

- ◆ test is not accredited
- test is subcontracted within Eurofins group and is accredited
- test is subcontracted within Eurofins group and is not accredited
- test is subcontracted outside Eurofins group and is accredited
- test is subcontracted outside Eurofins group and is not accredited
- * result is off-specs

N/A means Not Applicable

N/D means Not Detected

est means Estimated Count

The result(s) relate(s) only to the item(s) tested.

The report shall not be reproduced except in full unless authorized by Eurofins Mechem Pte Ltd.

The report must not be used for advertising purposes.

Eurofins General Terms and Conditions apply.

 Passed/Satisfactory: The Measured Values were observed in **tolerance** at the points tested.

Failed/Unsatisfactory: One or more Measured Values were observed out of tolerance at the points tested.

-- End of Report --